



January 19, 2021

Village of Belle Plaine  
P.O. Box 63  
Belle Plaine, SK,  
S0G 0G0

Dear Waterworks Owner/Operator:

**RE: Rescinding Precautionary Drinking Water Advisory – Village of Belle Plaine**

The Water Security Agency, in consultation with the Saskatchewan Health Authority-Moose Jaw Office, is advising that the ***“Precautionary Drinking Water Advisory” (PDWA)*** issued for the Village of Belle Plaine’s distribution system has been rescinded, as of January 19, 2021.

The rescinding of the PDWA was based upon information provided by your community, which included:

- Chlorine residuals throughout the WTP and distribution system are within regulatory requirements; and
- Bacteriological sampling is within regulatory limits.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Village of Belle Plaine in addressing the advisory.

For further information please do not hesitate to contact the undersigned at (306) 630-8476 or [aleena.james@wsask.ca](mailto:aleena.james@wsask.ca).

Sincerely,

A handwritten signature in blue ink, appearing to read "Aleena James".

WATER SECURITY AGENCY  
Aleena James – E.I.T., M.Eng.  
Environmental Project Officer  
Environmental Services Section - South  
Environmental and Municipal Management Services Division

cc: Greg Holovach, Water Security Agency  
Water Advisories, Water Security Agency  
Saskatchewan Health Authority, Moose Jaw